

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE J	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0005		3. EFFECTIVE DATE 22-May-2003	4. REQUISITION/PURCHASE REQ. NO. W26GLG-2253-0525		5. PROJECT NO.(If applicable) MUHJ 033006
6. ISSUED BY CODE DACA65  CONTRACTING OFFICE (CA/CW) US ARMY ENGR DIST NORFOLK ATTN: CENAO-SS-C 803 FRONT STREET NORFOLK VA 23510-1096		7. ADMINISTERED BY (If other than item 6) CODE  <b>See Item 6</b>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. DACA65-02-R-0041	
				<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) 24-Sep-2002	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE		11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS	
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) AMENDMENT NO. 0005 to DACA65-02-R-0041, Storm Drainage, Langley Air Force Base, VA.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  22-May-2003

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**The following items are applicable to this modification:**CONTINUATION

1. Proposals are due in the Norfolk District, Corps of Engineers, 803 Front Street, Norfolk, VA 23510-1096 at 11:00 AM.
2. Technical specifications and drawings are amended in accordance with the following:
  1. SECTION 01451A:
    - a. Revise Para 3.4.2 CQC System Manager to read as follows:  
... “The CQC System Manager shall be assigned as System Manger as his sole duties.”...
    - b. Revise Para 3.4.3 CQC Personnel to read as follows:
      - 1.) “In addition to CQC personnel specified elsewhere in the contract, the Contractor shall provide as part of the CQC organization specialized personnel to assist the CQC System manager for the following areas: electrical/mechanical, civil, structural, and environmental.”...
      - 2.) “b. Mechanical/Electrical” ...
      - 3.) “c. Electrical/Mechanical”...
  2. SECTION 02222:
    - a. Revise Para. 2.6.b. Flowable Backfill Mix. Design to read as follows:  
“Mix design for flowable backfill shall be provided by the Contractor. When used as backfill material in pipe installations or in other uses at locations as designated on the plans flowable backfill shall have a design compressive strength of 30 to 200 psi. When used as backfill material for plugging designated abandoned pipes and culverts flowable backfill shall have a design compressive strength of 30 to 1200 psi. The design compressive strength requirement shall be at 28 days when tested in accordance with ASSHTO T-23. Mix design shall result in a fluid product having no less than an 8-inch slump at time of placement. The Contractor shall submit a mix design for approval supported by laboratory test data verifying compliance with 28-day compressive strength requirements. Mix design shall be approved prior to placement.
3. Sheet C-029: Utility Adjustment Sheet
  - a. Add the following notes:
    1. Adjustment Foam Drain line using same pipe size and materials as original construction.
    2. Use standard PVC threaded clean out for closure of 8” PVC.”
4. SECTION 01005
  - a. Delete Para. 1.5.4.a. which reads as follows:

“Road closure for work on Andrews Street shall be a maximum of 90 calendar days.”

5. SECTION 02630a

a. Revise Para. 3.8 Pipeline Testing to read as follows:

“...Leakage as measured by either the infiltration test or exfiltration test shall not exceed 25 gallons per inch diameter per mile of pipeline per day.”

6. Sheet S-201: Building Sections & Elevations

a. Add Detail per sketch SK016.