

| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | | 1. CONTRACT ID CODE J | PAGE OF PAGES 1 2 |
|---|----------------------------------|---|--|---|---|
| 2. AMENDMENT/MODIFICATION NO. 0005 | 3. EFFECTIVE DATE 31-Dec-2002 | 4. REQUISITION/PURCHASE REQ. NO. W26GLG-2316-3441 | | 5. PROJECT NO.(If applicable) MUHJ 940300A | |
| 6. ISSUED BY CONTRACTING OFFICE (CA/CW) US ARMY ENGR DIST NORFOLK ATTN: CENAO-SS-C 803 FRONT STREET NORFOLK VA 23510-1096 | CODE DACA65 | 7. ADMINISTERED BY (If other than item 6) See Item 6 | | CODE | |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code) | | | | X | 9A. AMENDMENT OF SOLICITATION NO. DACA65-03-R-0005 |
| | | | | X | 9B. DATED (SEE ITEM 11) 18-Nov-2002 |
| | | | | | 10A. MOD. OF CONTRACT/ORDER NO. |
| | | | | | 10B. DATED (SEE ITEM 13) |
| CODE | FACILITY CODE | | | | |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | | | |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. | | | | | |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required) | | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14. | | | | | |
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. | | | | | |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B). | | | | | |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | | | | | |
| D. OTHER (Specify type of modification and authority) | | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office. | | | | | |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) AMENDMENT NO. 0005 TO DACA65-03-R-0005, REPLACE HOUSING MANAGEMENT OFFICE, LANGLEY AIR FORCE BASE, VA. | | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect. | | | | | |
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | | |
| | | | TEL: _____ EMAIL: _____ | | |
| 15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign) | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer) | | 16C. DATE SIGNED 31-Dec-2002 | |

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

CONTINUATION

Technical plans and specifications are amended. Make appropriate changes in accordance with the attached.

DIVISION 01 GENERAL REQUIREMENTS

SECTION 01330 - SUBMITTAL PROCEDURES

SUBMITTAL REGISTER (Located at end of this section)

Page 2 of 28, for Column (c) Section 02220 and Column (d) SD-03 Product Data add the following below Work Plan, "Playground Equipment Photographic Survey", add to Column (e) "1.3", and add to Column (f) "G".

DIVISION 02 SITE WORK

SECTION 02220 - DEMOLITION

Paragraph 1.3 Submittals

SD-03 Product Data

Add the following below the paragraph ending "...in accordance with EM 385-1-1:"

"Playground Equipment Photographic Survey; G

Prior to the commencement of demolition work, the Contractor shall produce a photographic survey of the condition of the existing playground equipment. The Contractor shall provide one copy to the Contracting Officer and retain one copy on site. The survey shall establish the benchmark for the condition of the existing playground equipment when it is installed in the new playground location."

SECTION 02361A – EXCAVATION, TRENCHING AND BACKFILLING FOR UTILITIES

Paragraph 2.1.2 Unsatisfactory Materials

At the end of the sentence "...frozen material, and stones larger than 3 inches." ; delete the period and add "in any dimension."

Paragraph 3.1.1 Trench Excavation Requirements

In the first sentence, delete "... 'Safety Manual for Trenching' of ..." and add "... 'Health and Safety Manual; EM385-1-1' for..."

SECTION 02630A - STORM DRAINAGE SYSTEM

Paragraph 2.2.3.2 Frame and Cover for Gratings

Add "or" following... ASTM A 48, Class 35B; and delete "or cast aluminum, ASTM B 26/B 26M, Alloy 356.OT6."

SECTION 02770A – CONCRETE SIDEWALKS AND CURBS AND GUTTERS

Paragraph 1.2 Submittals

Delete SD-06 Test Reports in its entirety and add the following:

“SD-06 Test Reports

Field Quality Control; G

The Contractor shall submit copies of the Testing Laboratory report to the Contracting Officer within 24 hours of the conclusion of tests. The Contractor shall submit six copies of test results.”

DIVISION 03 CONCRETE

SECTION 03307A – CONCRETE FOR MINOR STRUCTURES

PART 2 PRODUCTS

Paragraph 2.1.5 Reinforcing Steel

Delete Paragraph 2.1.5 in its entirety and add the following:

“2.1.5 Reinforcing Steel

Reinforcing steel bar shall conform to the requirements of ASTM A 615/A 615M, Grade 60. Welded steel wire fabric shall conform to the requirements of ASTM A 185, and shall be furnished in flat sheets only. Details of reinforcement not shown shall be in accordance with ACI 318/318 R, Chapters 7 and 12.”

DIVISION 06 WOOD AND PLASTICS

SECTION 06100A - ROUGH CARPENTRY

PART 3 EXECUTION

Paragraph 3.4 Installation of Vapor Retarder

Add the following to the end of the paragraph: "The vapor barrier shall be installed between the steel studs and interior gypsum board finish."

DIVISION 10 SPECIALTIES

SECTION 10990 - MISCELLANEOUS SPECIALTIES

PART 2 PRODUCTS

Add the following paragraph:

"2.3 TELEVISION MOUNTS

Mounting hardware for the mounts shall be suspended ceiling mounting where indicated on the drawings. TV monitor mounting hardware shall be fabricated of heavy 11-gauge steel and shall be MIG welded. The bottom mounting plates shall be adjustable for "fine turning" of the center of gravity in relation to the degree of tilt desired. All mounts shall be UL listed. For 27 inch monitors, provide jumbo yoke mount units with bottom mounting tray. Mount the top yoke of the monitor mount within 2 inches of the finished ceiling. Coordinate the size of the mounts with the size of the monitors as directed by the Contracting Officer."

DIVISION 12 FURNISHINGS

SECTION 12490A – WINDOW TREATMENTS

Paragraph 1.3 General

In the second sentence, delete "...in accordance with paragraph WINDOW TREATMENT SCHEDULE." And add "...for Type B windows as indicated on the drawings."

DIVISION 16 ELECTRICAL

SECTION 16175 ANALOG ADDRESSABLE FIRE DETECTION AND ALARM SYSTEM

Delete Section 16175 in its entirety.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.4

Replace Dwg. C-101 dated 11-26-02 with Dwg. C-101 dated 12/16/02 Amendment #1.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.11

Under CONCRETE MASONRY NOTES add the following note:

13. Electrical conduit runs shall be prohibited within reinforced masonry cells.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.13

Replace Dwg. S-101 dated 11-26-02 with Dwg. S-101 dated 12/16/02 Amendment #1.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.19

On SHEET KEYNOTE No. 7, delete the word EXTINGUISHER and replace with EXTINGUISHER.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.23

Replace Dwg. A-301 dated 11-26-02 with Dwg. A-301 dated 12/16/02 Amendment #1.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.24

Add GENERAL NOTE:

1. Provide continuous vapor barrier at interior face of 6" metal studs.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.25

Add GENERAL NOTE:

1. Provide continuous vapor barrier at interior face of 6" metal studs.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.26

Replace Dwg. A-304 dated 11-26-02 with Dwg. A-304 dated 12/16/02 Amendment #1.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.31

On Detail D1/A503 change the title reference bubble by deleting the drawing cut designation A301 and add A304.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.37

Delete the TV symbol in Break Room A109 on Dwg. I-101.

REPLACE HOUSING MANAGEMENT OFFICE
LANGLEY AFB, HAMPTON, VIRGINIA
PROJECT NO. MUHJ940300A
PAGE 5 OF 5

ON NORFOLK DISTRICT DWG. NO. LF-449-1.50

Replace Dwg. E-001 dated 11-26-02 with Dwg. E-001 dated 12/16/02 Amendment #1.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.51

Replace Dwg. E-101 dated 11-26-02 with Dwg. E-101 dated 12/16/02 Amendment #1.

ON NORFOLK DISTRICT DWG. NO. LF-449-1.52

Replace Dwg. E-102 dated 11-26-02 with Dwg. E-102 dated 12/16/02 Amendment #1.