

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT (Nonappropriated Funds)

For use of this form, see AR 215-4; proponent agency is ODCSPER

1. AMENDMENT/MODIFICATION NO. 0005 2. EFFECTIVE DATE 4 February 2004 3. REQUISITION/PURCHASE REQUEST NO. 4. PROJECT NO. (If applicable)

5. ISSUED BY Contracting Office (CENAO-SS-C) US Army Engineer District, Norfolk 803 Front Street Norfolk, VA 23510

6. ADMINISTERED BY (If other than block 5)

7. CONTRACTOR NAME AND ADDRESS (Include Street, City, County, State, and ZIP Code)

Empty rectangular boxes for contractor name and address.

8. AMENDMENT/MODIFICATION AMENDMENT OF SOLICITATION DATED December 19, 2003 NO. NAFTS3-04-R-0009

MODIFICATION OF CONTRACT/ ORDER DATED NO.

9. THIS BLOCK APPLIES ONLY TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in block 12. The hour and date specified for receipt of Offers is extended, X is not extended.

(a) By signing and returning 1 copies of this amendment; (b) by acknowledging receipt on each copy of the offer submitted; or (c) by separate letter or telegram which includes a reference to the solicitation and amendment numbers.

10. NO APPROPRIATED FUNDS OF THE UNITED STATES SHALL BECOME DUE, OR BE PAID, THE CONTRACTOR BY REASON OF THIS CONTRACT.

11. THIS BLOCK APPLIES ONLY TO MODIFICATIONS OF CONTRACT/ORDERS

- (a) This Change Order is issued pursuant to The Changes set forth in block 12 are made to the above numbered contract/order. (b) The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, etc.) set forth in block 12. (c) This Supplemental Agreement modifies the above numbered contract as set forth in block 12.

12. DESCRIPTION OF AMENDMENT/MODIFICATION

YOUTH ACTIVITY CENTER, LANGLEY AIR FORCE BASE, VIRGINIA is amended as follows:

1. SECTION L - ADDENDUM, page 00110-3, paragraph (4) is amended to read as shown below:

(4) Factor 4: Price. This information should be submitted in an envelope labeled "Pro Forma Requirements." This category consists of representations and certifications, subcontracting plan, completed DA FORM 4069-R and schedule of proposed prices. Provide original and two (2) copies.

2. Plans and specifications are amended to add the following clarifications.

Except as provided herein, all terms and conditions of the document referenced in block 8, as heretofore changed, remain unchanged and in full force and effect.

13. SIGNATURE REQUIREMENT

- CONTRACTOR/OFFEROR IS NOT REQUIRED TO SIGN THIS DOCUMENT. CONTRACTOR/OFFEROR IS REQUIRED TO SIGN THIS DOCUMENT AND RETURN COPIES TO ISSUING OFFICE

14. NAME AND SIGNATURE OF CONTRACTING OFFICER DATE SIGNED

15. NAME OF CONTRACTOR/OFFEROR (Signature of person authorized to sign)

16. NAME AND TITLE OF CONTRACTOR/OFFEROR DATE SIGNED

# DRAWINGS

## DRAWING A800 - DOOR SCHEDULE

Door 103	Change "Frame" column to Type 3.
Door 137	Change "Frame" column to Type 2
Door 137A	Change "Frame" column to Type 2
Door 139	Change "W" (width) column to PR3'-0".
Door 147B	Change "W" (width) column to 5'-0".

## DRAWING A101/A102 – CLARIFICATION

Note 4. Provide Television Mounting Brackets at all locations of Cable Television System Outlets as indicated on sheets E401 and E402.

There are no basketball goals intended to be installed in room 139.

## DRAWING A300 – EXTERIOR COLOR SCHEUDLE

Change item "2. BRICK MORTAR" to be" LEIGH HIGH #00024".

## DRAWING A902

Details 3 & 4/A902. Change bullnose trim material noted as, "3/4" PLYWOOD WITH HPL-8" on detail 4/A902 and "HPL-8" on detail 3/A902, to "SOLID MAPLE TRIM WITH CLEAR FINISH".

## DRAWING A901 - CLARIFICATION

Delete Signage General Note 7 and replace with the following:

PROVIDE AND INSTALL THE FOLLOWING SIGN IN A LOCATION TO BE DETERMINED BY THE GOV.:

"ATTENTION ALL PERSONNAL AND VISITORS

IT IS A FEDERAL CRIME TO KNOWINGLY POSSESS OR CASUE TO BE PRESENT, A FIREARM OF OTHER DANGEROUS WEAPON IN THIS FACILITY. THE LAWFUL PERFORMANCE OF OFFICIAL DUTIES AUTHORIZED BY LAW IS EXEMPT. VIOLATERS WILL BE PROSECUTED TO THE FULLEST EXTENT OF THE LAW."

This sign shall be fabricated of the same material specified for interior room identification signage.

## DRAWING A905

Note 3. (Added by addendum). Add the following statement:  
"WWF shall be 6x6 – W2.2 x W2.0. Provide 4" porous fill (sand).

Clarification – The "6" Concrete Pad" dimensions are 25'-0" x 20'-6" as indicated on this sheet.

Clarification – Detail 1/A905.

Elevation of concrete sidewalk shall match top of curb indicated on the plan.  
Playground surface shall match sidewalk elevation where playground surface  
and sidewalk abut.

#### **DRAWING S-104 – CLARIFICATION**

Note E. This is a general note.

#### **DRAWING M-202**

Provide a 4” duct at room 115 with connection for a dryer. Extend ductwork  
through. Terminate duct with a 8” dome in accordance with detail 3/A500.

## **SPECIFICATIONS**

#### **Section 03300 –Cast-in-Place Concrete**

Paragraph 3.1.3. Delete the following sentence from 03300 3.1.3:  
“A 2 inch layer of compacted, clean concrete sand....before placing concrete.

#### **Section 05500A – Miscellaneous Metals**

Paragraph 2.4. Add the following statement”  
“Provide one 6’-0” x 8’-0” mat in room 100 Vestibule.”

#### **Section 10990 – Miscellaneous Specialties**

Paragraph 2.7 (added via addendum). Change the second sentence to read,  
“Model DSWP6103.

Paragraph 2.7 (added via addendum). Add the following statement:  
“Coordinate mounting height with Contractor Officer.”